

BREECHINGS, CHIMNEY, AND STACKS FOR CONDENSING APPLIANCES
DIVISION 23 51 23

PART 1- GENERAL

1.1 SUMMARY

- A. Section Includes:
1. Venting for the removal of products of combustion for Category II, III, IV gas burning appliances

1.2 REFERENCES

- A. Underwriters Laboratories (UL):
1. UL1738
- B. National Fire Protection Association (NFPA):
1. NFPA 54 – National Fuel Gas Code
 2. NFPA 211 – Standard for Chimneys, fireplaces, Vents, and Solid Fuel-Burning Appliances.

1.3 QUALITY ASSURANCE

- A. Comply with NFPA 54
- B. Must install duct in accordance to manufacturer's listings and installation instructions.
- C. Components coming in contact with the products of combustion shall carry the appropriate UL or cUL listing, mark or label

1.4 WARRANTY

- A. Condensing Appliance vent listed to UL1738 shall have a limited lifetime warranty to begin at the date of installation. Any portion of the vent repaired or replaced under warranty shall be warranted for the remainder of the original warranty period.

PART 2- PRODUCTS

2.1 AVAILABLE MANUFACTURERS

- A. Listed Single-Wall vent for condensing appliances, Model FCSSW/CGSW, as manufactured by Metal-Fab, Inc.

2.2 LISTED VENTING FOR CONDENSING APPLIANCES

- A. The condensing appliance vent shall be single-wall construction for use with Category II natural draft appliances and Category III or IV positive pressure appliances.
- B. Maximum temperature shall not exceed 550° F (288° C).
- C. Vent shall be listed for an internal static pressure of 15 inches w.g. and tested to 37.5 inches w.g. for diameters 3 to 36 inch.
- D. Vent shall be constructed of AL29-4C material tested to UL1738, .015 inch thickness for 3 inch to 12 inch diameters, .024 inch thickness for 14 inch to 24 inch diameters, and .035 inch thickness for 26 inch to 36 inch diameters.
- E. Joint assembly utilizes flanged mating surfaces, with a self-guiding sleeve for diameters 6 inch - 24 inch. P070 sealant will be used on the flange surface and in the vee band. Flanges are joined with a vee band secured by tightening draw bolts. Diameters 3-5 inch utilize an overlapping snap-lock, Viton gasket joint connection.

PART 3-EXECUTION

3.1 STORAGE AND CONSTRUCTION

- A. Protect materials from accidental damage.
- B. All supports, roof or wall penetrations, terminations, appliance connectors and drain fittings required to install the vent system shall be included.
- C. Vent shall terminate in accordance with installation instructions and local codes.
- D. Installation shall conform to manufacturer's installation instructions.